



BM TRADA, Q - MARK FIRE DOOR MANUFACTURER CERTIFICATE







CERTIFICATE OF REGISTRATION

This is to certify that

Greenlam Industries Limited

2nd Floor, West Wing, Worldmark,1 Tower A, Aerocity, IGI Airport Hospitality District New Delhi-110 037 India

Meets the requirements of the BM TRADA **Q-Mark Fire Door Manufacture** scheme to **STD006**

Steve Roberts
Product Certification Operations Manager
For and on behalf of BM TRADA

Certificate Number

1067

Date of Initial Certification 06/04/2017

Date of Last Issue 05/09/2023

Date of Expiry 05/04/2026

BM TRADA is a trading name of Warringtonfire Testing and Certification Limited, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND,

Registered Office: Warringtonfire Testing and Certification Limited, 3rd Floor, Davidson Building, 5 Southampton Street, London, WCZE 7HA, UK
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com



Registration Schedule

Head Office Address

2nd Floor, West Wing, Worldmark, 1 Tower A, Aerocity, IGI Airport Hospitality District New Delhi-110 037

Factory Address

E-176-179, SP-02, RIICO Industrial Area, Phase 2 Delhi-Jaipur National Highway No. 8 Behror Rajasthan 301 701 India

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this Q-Mark certified company are listed on the Q-Mark certificate along with the latest revision status. They are either used in isolation, or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Туре	FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Integrity Period	FoA Standard
Fire	WF509037	-	Greenlam Industries Ltd	Halspan Optima 30 Doorsets Part 1: Timber based		BS 476 Pt22
Smoke	N/A	-	-	frames for 30 minutes fire resistance. (Glazed or Unglazed)	30min	-

Please note:

- Field of application WF509037 replicates field of application Chilt/A01204 and must be updated concurrently.
- Associated document BMT/CNA/F15121 listed below cannot be used in conjunction with WF 509037.

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the Q-Mark certificate. The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry. They are either used in isolation, or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other.

Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

Туре	FoA Report	System Supplier owner of Assessment Report	Doorset Description	Integrity Period	FoA Standard
Fire	Chilt/A0120 4	Halspan Limited	Optima 30 Part 1 Timber (glazed or unglazed)	30min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	Chilt/A0120 5	Halspan Limited	Optima 60 (glazed or unglazed)	60min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	Chilt/A0515 1	Halspan Limited	Halspan 90 (glazed or unglazed)	90min	BS 476 Pt22
Smoke	N/A	-			N/A
Fire	BMT/CNA/F 15082	Halspan Limited	Halspan 120 (glazed or unglazed)	120min	BS 476 Pt22
Smoke	N/A	-			N/A

Test Reports

Test reports are listed on the Q-Mark certificate. They cannot be used in conjunction with any primary FoA reports, other test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Туре	Test Report	Owner of Test Report	Doorset Description	Integrity Period	Test Standard
Fire only	N/A	-	-	-	-



www.mikasadoors.com

