



FD60 MINS FIRE RATED DOOR CBRI, INDIA

TEST SCHEDULE 1/1 (Reference No. - FR /0700)

- 1. Name of the Laboratory
- 2. Name of the Sponsorer
- 3. Name of the Test
- 4. Date of Test
- 5. Ambient Temperature
- 6. Fire Exposure
- 7. Applicability of Test Criteria
- 8. Specimen Details
- 9. Specimen Construction
- 10. Door Type
- 11. Door Installation
- 12. Intended Test Duration

: Fire Research Laboratory CSIR-Central Building Research Institute,

Roorkee-247 667

: M/S Greenlam Industries,

E-176-179,SP-02 RIICO Industrial Area

Phase-II, Behror-Distt, Alwar

Rajasthan-301 701

: Fire Resistance Test

: February 24, 2021

: 23°C

: As per BS:476 (Part 20 & 22)-1987, IS:3614(Part-2)-1992

: Stability

Yes

: Integrity

Yes

: Insulation

Yes

: Single Leaf Single Swing Laminated Wooden Composite
Fire Door

Size

Door Frame

Door Panel

Height

2092 mm

2055 mm

Width

933 mm

866 mm

Thickness : 119 mm

55 mm

: As shown in Figure 1 and Figure 2 [Drg. No. 1/1 - 0700 (1) and 1/1- 0700 (2)]

: Insulated

: Opens towards the furnace chamber

: 60 Minutes

Test Results

The data of the evaluation reveals that the single leaf single swing laminated wooden composite fire door specimen has been found to be able to withstand standard fire exposure for 60 minutes (Sixty minutes only) with respect to stability, integrity and thermal insulation.

(Sushit Kumar)

(Narendra Kumar)

(Dr. Suvir Singh)

(Technical data provided in this schedule pertains to the specific sample submitted to the Institute and tested CBRI's name or logo cannot be used for commercial purposes. All procedural, legal, and / or operational matters will be the responsibility of the party using these results. Accepting / Rejecting the results, partly or fully rests with the users agencies.)





अञ्च अनुसंधान प्रयोगराला FIRE RESEARCH LABORATORY सी.एस.आई.आर. केन्द्रीय भवन अनुसंधान संस्थान CSIR - Central Building Research Institute

फडकी - 247 667 (उत्तराखण्ड) भारत/Roorkee - 247 667 (U.K.) INDIA

Note: This original only is valid. Third parties using copies are doing so at their own risk.







POSITION OF THERMOCOUPLES
 ALL DIMENSIONS ARE IN MM
 SCALE - N.T.S.

DRG. NO.	1/1 - 0700 (1)
DRWN. BY	Rayno Boursas
CHKD. BY	9/2

Fig. 1: Construction details of Single Leaf Single Swing Laminated Wooden Composite Fire Door (Mikasa Door) specimen evaluated for Fire Resistance on Feb. 24, 2021.



अधिन अनुसंधान प्रयोगरात्म FIRE RESEARCH LABORATORY सी.एस.आई.आर. - केन्द्रीय भवन अनुसंधान संस्थान CSIR - Central Building Research Institute

रूड़की - 247 667 (उत्तराखण्ड) भारत/Roorkee - 247 667 (U.K.) INDIA



Note: This original only is valid. Third parties using copies are doing so at their own risk.




Fig. 2: Sectional details of Single Leaf Single Swing Laminated Wooden Composite Fire Door (Mikasa Door) specimen evaluated for Fire Resistance on Feb. 24, 2021



अधिन अनुसंधान प्रयोगशाला FIRE RESEARCH LABORATORY

सी.एस.आई.आर.- केन्द्रीय भवन अनुसंधान संस्थान CSIR - Central Building Research Institute

फड़की - 247 667 (उत्तराखण्ड) भारत/Roorkee - 247 667 (U.K.) INDIA



Note: This original only is valid. Third parties using copies are doing so at their own risk.



www mikasadoors com

